



E
P
OH7902012
Job
M:
Scr

TCMSD-DUNDEE PWS

7/25/2011



July 25, 2011

RE: TUSCARAWAS COUNTY
TCMSD-DUNDEE
COMMUNITY
7901912 7902012

TCMSD-Dundee
Attn.: Charles Williams
9944 Wilkshire Blvd.
Bolivar, OH 44612

We have reviewed your Plant Distribution Monthly Operation Report covering the time period of June 2011 and have noted the following deficiencies:

The chlorine levels from the plant tap/distribution system were less than 0.2 mg/l for 8 days during the month.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions regarding this letter, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office/DDAGW, Toni Buchanan
cc: Tuscarawas County Health Department
cc: Jamie Wilkins, SEDO