




Environmental

Pro OH7900112

BALTIC VILLAGE PWS

10/24/2011

Joh  
Ma  
Sco



October 24, 2011

RE: Tuscarawas County  
Baltic Village PWS  
Community Water System  
PWS ID#OH7900112  
STU ID#OH7959264

Baltic Village PWS  
c/o Timothy Griffith  
102 West Main Street  
Baltic, OH 43804

**Notice of Violation**

Dear Mr. Griffith:

Ohio EPA received your September Monthly Operating Reports submitted on October 13, 2011, for the Baltic Village public water system, but there were several inconsistencies with the free chlorine residual noted in both the plant tap and distribution system and the submittal date.

**September MOR, received October 13, 2011:**

Your public water system is in violation of the Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1) for failure to maintain a 0.2 mg/L free or 1 mg/L combined chlorine residual. There were 9 instances in the plant tap and 6 within the distribution system where this situation occurred for the month.

The cause of the chlorine issue was identified as a weak batch of chlorine being used after a change in chemical suppliers. Free chlorine residuals have been maintained above 0.2 mg/L since the old chlorine was changed to the new supply.

**Submittal date for MOR: Late**

Monthly operating reports are required to be submitted to the Ohio EPA by the 10<sup>th</sup> of the month following the reporting month. The reference MOR was submitted on October 13, 2011.

Baltic Village PWS  
October 24, 2011  
Page 2

If you have any questions, please contact me at (740) 380-5229.

Sincerely,



Russell Flagg, REHS  
Environmental Specialist  
Division of Drinking and Ground Waters

RF/cb

cc: Central Office/DDAGW, Toni Buchanan  
Tuscarawas County Health Department  
Jamie Wilkins, SEDO