



Environmental

Pr

Jo

M

Sc

OH7901912

TCMSD-RIDGEWOOD PWS

10/21/2011



October 21 , 2011

RE: **Tuscarawas County**
TCMSD-Ridgewood PWS
Community Water System
PWS ID#OH7901912
STU ID#OH7959281

TCMSD-Ridgewood PWS
c/o Charles Williams
9944 Wilkshire Boulevard
Bolivar, OH 44612

Notice of Violation

Dear Mr. Williams:

Ohio EPA received your September Monthly Operating Reports submitted on October 6, 2011, for the TCMSD-Ridgewood public water system, but there were several inconsistencies with the free chlorine residual noted in the plant and distribution systems.

September MOR, received October 6, 2011:

Your public water system is in violation of the Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1) for failure to maintain a 0.2 mg/L free or 1 mg/L combined chlorine residual. There was 1 instance at the plant tap and 3 within the distribution system where this situation occurred for the month.

The free chlorine residuals have returned to compliance since days of non-compliance were identified.

If you have any questions, please contact me at (740) 380-5229.

Sincerely,


Russell Flagg, REHS
Environmental Specialist
Division of Drinking and Ground Waters

RF/cb

cc: Central Office/DDAGW, Toni Buchanan
Tuscarawas County Health Department
Jamie Wilkins, SEDO