



Environmental

P  
J  
N  
S

OH7902103

TCMSD-WAINWRIGHT PWS

10/21/2011



\* 0 H 7 9 0 2 1 0 3 1 0 2 1 2 0 1 1 N O V \*

October 21 , 2011

RE: Tuscarawas County  
TCMSD-Wainwright PWS  
Community Water System  
PWS ID#OH7902103  
STU ID#OH7959283

TCMSD-Wainwright PWS  
c/o Charles Williams  
9944 Wilkshire Boulevard  
Bolivar, OH 44612

**Notice of Violation**

Dear Mr. Williams:

Ohio EPA received your September Monthly Operating Reports submitted on October 6, 2011, for the TCMSD- Wainwright public water system, but there were several inconsistencies with the free chlorine residual noted in the plant and distribution systems.

**September MOR, received October 6, 2011:**

Your public water system is in violation of the Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1) for failure to maintain a 0.2 mg/L free or 1 mg/L combined chlorine residual. There were 3 instances at the plant tap where this situation occurred for the month.

The free chlorine residuals have returned to compliance since the days of non-compliance were identified.

If you have any questions regarding this letter, please contact me at (740) 380-5229.

Sincerely,

  
Russell Flagg, REHS  
Environmental Specialist  
Division of Drinking and Ground Waters

RF/cb

- cc: Central Office/DDAGW
- cc: Tuscarawas County Health Department
- cc: Jamie Wilkins, SEDO