




OH7901612

TCMSD-WILKSHIRE HILLS PWS

10/20/2011



October 20, 2011

RE: Tuscarawas County
TCMSD-Wilshire Hills PWS
Community Water System
PWS ID#OH7901612
STU ID#OH7959278

TCMSD-Wilshire Hills PWS
C/O Charles Williams
9944 Wilshire Boulevard
Bolivar, OH 44612

Notice of Violation

Dear Mr. Williams:

We have reviewed your Plant Distribution Monthly Operation Reports covering the time period of June, July, August and September 2011 and have noted the following violations:

Fluoride violations for June, July and September 2011:


- Fluoride was outside the required range of 0.8 to 1.3 mg/L for 2 days during the month of June, 2 days during the month of July and 2 days during the month of September in violation of the Ohio Revised Code 6109.20. Fluoride levels must always be in the range of 0.8 to 1.3 mg/L for optimum dental health.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

TCMSD-Wilkshire Hills PWS
October 20, 2011
Page 2

If you have any questions regarding this letter, please contact me at (740) 380-5229.

Sincerely,

A handwritten signature in black ink, appearing to read "Russell Flagg", written over a horizontal line.

Russell Flagg, REHS
Environmental Specialist
Division of Drinking and Ground Waters

RF/cb

cc: Central Office/DDAGW
cc: Tuscarawas County Health Department
cc: Jamie Wilkins, SEDO
cc: Chuck Williams
cc: Ed Wilson
cc: TCMSD
Tuscarawas County Commissioners
125 E. High Ave., New Philadelphia, OH 44663
cc: Colleen A. Wulf, RDH, MPH
Community-Based Prevention Specialist
Ohio Department of Health
Bureau of Oral Health Services
P.O. Box 118, Columbus, OH 43216-0118