


Environmental

OH7900112

BALTIC VILLAGE PWS

5/18/2011



May 18, 2011

RE: TUSCARAWAS COUNTY
BALTIC, VILLAGE OF
COMMUNITY WATER SUPPLY
I.D. NO. 7900112

Village of Baltic
Attn: Tim Griffith
P.O. Box 320
Baltic, OH 43804

Subject: Monthly Reporting

We have reviewed your Plant Distribution Monthly Operation Report covering the time period of April 2011, and have noted the following deficiencies:

- For Chlorine QOR Data, Total chlorine residual results equals the number of routine bacteria samples taken for the month (example 1), not 30. The average value in the case of one sample is just the sample result.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

A handwritten signature in black ink that reads "Randy R. Smith".

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office / DDAGW
cc: Tuscarawas Health Department
cc: Jamie Wilkins, SEDO