



January 25, 2011

**RE: TUSCARAWAS COUNTY
BALTIC, VILLAGE OF
COMMUNITY WATER SUPPLY
I.D. NO. 7900112**

Village of Baltic
Attn: Board of Public Affairs
P.O. Box 320
Baltic, OH 43804

Subject: Monthly Reporting

We have reviewed your Plant Distribution Monthly Operation Report covering the time period of December 2010, and have noted the following deficiencies:

- Chlorine levels were not analyzed at the plant tap as required on one day that water was produced. Distribution chlorine levels were not analyzed eight days during the month.
- Iron/Manganese QC Lab Check data must be collected in the same month that data is reported.
- Monthly flows were not reported for five days during the month.
- Chlorine levels were below the required limits from the plant tap for 8 days that data was reported and 2 days from the distribution system. These will be violations starting in January 2011.
- Total chlorine residual results= the number of routine bacteria samples (example 1, avg value = 1 total chlorine sample taken at time and location of routine bacteria sample).

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

- cc: Central Office / DDAGW
- cc: Tuscarawas Health Department
- cc: **Jamie Wilkins, SEDO**
- cc: Tim Griffith
- cc: Mayor and Council