



2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 29, 2010

**RE: TUSCARAWAS COUNTY
BALTIC, VILLAGE OF:
COMMUNITY WATER SUPPLY
I.D. NO. 7900112**

Village of Baltic
Attn: Board of Public Affairs
P. O. Box 320
Baltic, OH 43804

Subject: Monthly Reporting

We have reviewed your Plant Distribution Monthly Operation Report covering the time period of November 2010 and have noted the following deficiencies:

- Chlorine levels were not analyzed at the plant tap as required on fourteen days that water was produced. Distribution chlorine levels were not analyzed nine days during the month.
- Iron/Manganese QC lab check data was not provided.
- Monthly flows were not reported for nine days during the month.
- Chlorine levels were below the required limits from the plant tap for 12 days that data was reported and ten days from the distribution system. These will be violations starting in January 2011.
- Total chlorine residual results= the number of routine bacteria samples (example 1, avg value = 1 total chlorine sample taken at time and location of routine bacteria sample).

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office / DDAGW
cc: Tuscarawas Health Department
cc: Jamie Wilkins, SEDO
cc: Tim Griffith
cc: Mayor and Council