



Env
Pro

OH7900303

CHERRY RIDGE WATERWORKS, LTD.

2/28/2011

Joh
Mar
Scot



February 28, 2011

RE: **TUSCARAWAS COUNTY
CHERRY RIDGE WATERWORKS, LTD.
COMMUNITY PUBLIC WATER SYSTEM
PWS ID# OH7900303
STU ID# 7959266**

Cherry Ridge Waterworks, LTD.
Attn: Mary Ann Frey
1249 County Road 140
Sugarcreek, OH 44681

Subject: Monthly Reporting

We have reviewed your Plant Distribution Monthly Operation Report covering the time period of January 2011 and have noted the following deficiencies:

- Chlorine levels for January were below the minimum level of 0.2 mg/l free chlorine or 1.0 mg/l total chlorine for 25 days during the month.

Please take prompt action to correct these deficiencies in your next operational report. If chlorine levels cannot be maintained as required, supplemental chlorination will have to be installed.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office / DDAGW
cc: Tuscarawas Health Department
cc: **Jamie Wilkins, SEDO**