


E  
P

OH7900303

CHERRY RIDGE WATERWORKS, LTD.

1/24/2011



January 24, 2011

RE: **TUSCARAWAS COUNTY**  
**CHERRY RIDGE WATERWORKS, LTD.**  
**COMMUNITY PUBLIC WATER SYSTEM**  
**PWS ID# OH7900303**  
**STU ID# 7959266**

Cherry Ridge Waterworks, LTD.  
Attn: Mary Ann Frey  
1249 County Road 140  
Sugarcreek, OH 44681

Subject: Monthly Reporting


We have reviewed your Plant Distribution Monthly Operation Report covering the time period of December 2010 and have noted the following deficiencies:

- Chlorine levels for December were below the minimum level of 0.2 mg/l free chlorine or 1.0 mg/l total chlorine for 10 days during the month.

Please take prompt action to correct these deficiencies in your next operational report. If chlorine levels cannot be maintained as required, supplemental chlorination may have to be installed.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,



Randy R. Smith  
Environmental Specialist  
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office / DDAGW  
cc: Tuscarawas Health Department  
cc: **Jamie Wilkins, SEDO**