



2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 22, 2010

RE: **TUSCARAWAS COUNTY
CHERRY RIDGE WATERWORKS, LTD.
COMMUNITY PUBLIC WATER SYSTEM
PWS ID# OH7900303
STU ID# 7959266**

Cherry Ridge Waterworks, LTD.
Attn: Mary Ann Frey
1249 County Road 140
Sugarcreek, OH 44681

Subject: Monthly Reporting

We have reviewed your Plant Distribution Monthly Operation Report covering the time period of October and November 2010 and have noted the following deficiencies:

- Chlorine levels for October were below the minimum level of 0.2 mg/l free chlorine or 1.0 mg/l total chlorine for 27 days and for November were below the minimum level of 0.2 mg/l free chlorine or 1.0 mg/l total chlorine for 11 days.

Please take prompt action to correct these deficiencies in your next operational report. If chlorine levels cannot be maintained as required, supplemental chlorination may have to be installed.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office / DDAGW
cc: Tuscarawas Health Department
cc: **Jamie Wilkins, SEDO**