



TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 18, 2008

Re: Tuscarawas County
Gnadenhutten Village PWS
Community
7900512

Village of Gnadenhutten
Mike Heil, Operator
PO Box 129
Gnadenhutten, OH 44629

We have reviewed your Plant Distribution Monthly Operation Report covering the time period of June 2008 and have noted the following deficiencies:

For 14 day the free chlorine residual was reported at 2.2 mg/l. It appears that the chlorine analyzer is set on the low range. The chlorine analyzer should be set on the high range or samples must be diluted so you can get an accurate reading.

No flow readings were reported for 9 days and no reason was given for not reporting.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office/DDAGW
cc: Tuscarawas County Health Department
cc: Jamie Wilkins, SEDO
cc: Gary Taylor