

\* O H 7 9 D 0 5 1 2 8 2 4 2 0 0 7 N O V \*  
TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us2195 Front Street  
Logan, Ohio 43138Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

August 24, 2007

Re: TUSCARAWAS COUNTY  
GNADENHUTTEN VILLAGE PWS  
COMMUNITY  
OH7900512 ?GNADENHUTTEN, VILLAGE OF  
148 WEST MAIN STREET  
PO BOX 129  
GNADENHUTTEN, OH 44629

We have reviewed your Plant Distribution Monthly Operation Report covering the time period of July 2007 and have noted the following deficiencies:

- Iron and manganese levels were not analyzed as required.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith  
Environmental Specialist  
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office/DDAGW  
cc: Tuscarawas County Health Department  
cc: Jamie Hedges, SEDO  
cc: Chris Edwards, PO Box 702, Gnadenuhuten, OH 44629