



2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Laura H. Powell, Acting Director

January 17, 2007

Re: Tuscarawas County
Midvale Village PWS
Community
7900612

Village of Midvale
PO Box 2
Midvale, OH 44653

We have reviewed your Plant Distribution Monthly Operation Report, Total Chlorine Residual Quarterly Operating Report and Microbiological Contaminant Monthly Operation Report covering the time period of December 2006 and have noted the following deficiencies:

- The combined chlorine residual in the distribution system/plant tap is not being reported as required in the Ohio Administrative Code.
- All reports must include the current operator certification number.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office/DDAGW
cc: Tuscarawas County Health Department
cc: Jamie Hedges, SEDO
cc: Jim Sims