




E
P
C
I
S

OH7901912

TCMSD-RIDGEWOOD PWS

2/28/2011



February 28, 2011

RE: TUSCARAWAS COUNTY
TCMSD-RIDGEWOOD
COMMUNITY
7901912

TCMSD-Ridgewood
Attn.: Charles Williams
9944 Wilkshire Blvd.
Bolivar, OH 44612

We have reviewed your Plant Distribution Monthly Operation Report covering the time period of January 2011 and have noted the following deficiencies:

The chlorine level from the plant tap was less than 0.2 mg/l for six days.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions regarding this letter, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office/DDAGW, Toni Buchanan
cc: Tuscarawas County Health Department
cc: Jamie Wilkins, SEDO