



May 18, 2011

RE: TUSCARAWAS COUNTY  
TCMSD-RIDGEWOOD  
COMMUNITY  
7901912

TCMSD-Ridgewood  
Attn.: Charles Williams  
9944 Wilkshire Blvd.  
Bolivar, OH 44612

We have reviewed your Plant Distribution Monthly Operation Report covering the time period of April 2011 and have noted the following deficiencies:

The chlorine level from the plant tap was less than 0.2 mg/l for four days.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions regarding this letter, please contact me at (740) 380-5275.

Sincerely,

A handwritten signature in black ink, appearing to read 'Randy R. Smith', is written over the typed name.

Randy R. Smith  
Environmental Specialist  
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office/DDAGW, Toni Buchanan  
cc: Tuscarawas County Health Department  
cc: Jamie Wilkins, SEDO;