


Er  
Pr  
Jc  
M  
Sc

OH7902103

TCMSD-WAINWRIGHT PWS

9/12/2011



September 12, 2011

RE: Tuscarawas County  
TCMSD – Wainwright PWS  
Community Water System  
PWS ID#OH7902103  
STU ID#OH7959283

Mr. Charles D. Williams  
9944 Wilkshire Boulevard  
Bolivar, Ohio 44612

**Notice of Violation**


Dear Mr. Williams:

Ohio EPA received your August Monthly Operating Report on September 7, 2011, for the Wainwright public water system, but there were several inconsistencies with the free chlorine residual noted in both the plant tap and distribution system.

Your public water system is in violation of the Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1) for failure to maintain a 0.2 mg/L free or 1 mg/L combined chlorine residual. There was 1 instance in the distribution system and 4 at the plant tap where this situation occurred for the month.

If you have any questions, please contact me at (740) 380-5229.

Sincerely,

  
Russell Flagg, REHS  
Environmental Specialist  
Division of Drinking and Ground Waters

RF/cb

cc: Central Office/DDAGW, Toni Buchanan  
Tuscarawas County Health Department  
Jamie Wilkins, SEDO