



TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

2195 Front Street  
Logan, Ohio 43138

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

June 15, 2010

**Re: Tuscarawas County  
TCMSD-Wilksire Hills PWS  
Community  
PWS ID# 7901612**

Tuscarawas County Sewer District  
9944 Wilksire Boulevard NE  
Bolivar, OH 44612

We have reviewed your Fluoride Adjustment Monthly Operation Report covering the time period of April-May 2010 and have noted the following violations:

- Fluoride was outside the required range of 0.8 - 1.3 mg/L for 13 days, during the months of April-May in violation of the Ohio Revised Code 6109.20. Fluoride levels must always be in the range of 0.8 - 1.3 mg/L for optimum dental health.

Chapter 6109 of the Ohio Revised Code (ORC) provides for civil penalties of up to \$25,000.00 per day of violation of the drinking water rules noted above. Should the TCMSD-Wilksire Hill's fail to correct its violations, Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action.

Please take prompt action to correct these violations. Failure to correct these violations could result in legal action.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith  
Environmental Specialist  
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office/DDAGW  
cc: Tuscarawas County Health Department  
cc: Jamie Wilkins, SEDO  
cc: Chuck Williams  
cc: Ed Wilson  
cc: TCMSD  
Tuscarawas County Commissioners  
125 E. High Ave., New Philadelphia, OH 44663  
cc: Colleen A. Wulf, RDH, MPH  
Community-Based Prevention Specialist  
Ohio Department of Health  
Bureau of Oral Health Services  
P.O. Box 118, Columbus, OH 43216-0118