



2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

April 29, 2010

Re: **Tuscarawas County
TCMSD-Wilkshire Hills PWS
Community
PWS ID# 7901612**

Tuscarawas County Sewer District
9944 Wilkshire Boulevard NE
Bolivar, OH 44612

We have reviewed your Fluoride Adjustment Monthly Operation Report covering the time period of March 2010 and have noted the following violations:

- Fluoride was outside the required range of 0.8 - 1.3 mg/L for 7 days, during the month, in violation of the Ohio Revised Code 6109.20. Fluoride levels must always be in the range of 0.8 - 1.3 mg/L for optimum dental health.

Chapter 6109 of the Ohio Revised Code (ORC) provides for civil penalties of up to \$25,000.00 per day of violation of the drinking water rules noted above. Should the TCMSD-Wilkshire Hill's fail to correct its violations, Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action.

Please take prompt action to correct these violations. Failure to correct these violations could result in legal action.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office/DDAGW
cc: Tuscarawas County Health Department
cc: **Jamie Wilkins, SEDO**
cc: Chuck Williams
cc: Ed Wilson
cc: TCMSD
Tuscarawas County Commissioners
125 E. High Ave., New Philadelphia, OH 44663
cc: Colleen A. Wulf, RDH, MPH
Community-Based Prevention Specialist
Ohio Department of Health
Bureau of Oral Health Services
P.O. Box 118, Columbus, OH 43216-0118