



2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

January 12, 2010

Re: Tuscarawas County
TCMSD-Wilkshire Hills PWS
Community
PWS ID# 7901612

Tuscarawas County Sewer District
9944 Wilkshire Boulevard NE
Bolivar, OH 44612

We have reviewed your Fluoride Adjustment Monthly Operation Report covering the time period of December 2009 and have noted the following violations:

- Fluoride was outside the required range of 0.8 - 1.3 mg/L for 8 days, during the month, in violation of the Ohio Revised Code 6109.20. Fluoride levels must always be in the range of 0.8 - 1.3 mg/L for optimum dental health.

Please take prompt action to correct these violations. Failure to correct these violations could result in legal action.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office/DDAGW
cc: Tuscarawas County Health Department
cc: Jamie Wilkins, SEDO
cc: Chuck Williams
cc: Colleen A. Wulf, RDH, MPH
Community-Based Prevention Specialist
Ohio Department of Health
Bureau of Oral Health Services
P.O. Box 118
Columbus, OH 43216-0118