



2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 18, 2009

RE: **TUSCARAWAS COUNTY**
TCMSD-WILKSHIRE HILLS
COMMUNITY
7901612

TCMSD-Wilshire Hills
Attn.: Charles Williams
9944 Wilshire Blvd.
Bolivar, OH 44612

We have reviewed your Plant Distribution Monthly Operation Report covering the time period of November 2009 and have noted the following deficiencies:

The chlorine level from the distribution system tap was less than 0.2 mg/l for one day.

The fluoride level from the plant tap was outside the range of 0.8 to 1.3 mg/l for four days.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions regarding this letter, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office/DDAGW, Toni Buchanan
cc: Tuscarawas County Health Department
cc: **Jamie Wilkins, SEDO**