



TELE: (740) 385-8501 FAX: (740) 385-9490  
www.epa.state.oh.us

2195 Front Street  
Logan, Ohio 43138

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

July 16, 2007

Re: **Tuscarawas County**  
**TCMSD-Wilshire Hills PWS**  
**Community**  
**PWS ID# 7901612**

Tuscarawas County Sewer District  
9944 Wilshire Boulevard NE  
Bolivar, OH 44612

We have reviewed your Fluoride Adjustment Monthly Operation Report covering the time period of June 2007 and have noted the following violations:

- Fluoride was outside the required range of 0.8 - 1.3 mg/L for 5 days, during the month, in violation of the Ohio Revised Code 6109.20. Fluoride levels must always be in the range of 0.8 - 1.3 mg/L for optimum dental health.

Please take prompt action to correct these violations. Failure to correct these violations could result in legal action.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

*Randy R. Smith*

Randy R. Smith  
Environmental Specialist  
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office/DDAGW  
cc: Tuscarawas County Health Department  
cc: ~~Jamie Hedges, SEDO~~  
cc: Chuck Williams  
cc: Colleen A. Wulf, RDH, MPH  
Community-Based Prevention Specialist  
Ohio Department of Health  
Bureau of Oral Health Services  
P.O. Box 118  
Columbus, OH 43216-0118