



2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

April 23, 2007

Re: ~~Tuscarawas County~~
~~TCMSD-Wilshire Hills PWS~~
~~Community~~
~~PWSID# 7901612~~

Tuscarawas County Sewer District
9944 Wilkshire Boulevard NE
Bolivar, OH 44612

We have reviewed your Fluoride Adjustment Monthly Operation Report covering the time period of March 2007 and have noted the following violations:

- Fluoride was outside the required range of 0.8 - 1.3 mg/L for 12 days, during the month, in violation of the Ohio Revised Code 6109.20. Fluoride levels must always be in the range of 0.8 - 1.3 mg/L for optimum dental health.
- No samples were collected for two days during the month.

Please take prompt action to correct these violations. Failure to correct these violations could result in legal action.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office/DDAGW
cc: Tuscarawas County Health Department
cc: ~~Jamie Hedges, SEDO~~
cc: Chuck Williams
cc: Colleen A. Wulf, RDH, MPH
Community-Based Prevention Specialist
Ohio Department of Health
Bureau of Oral Health Services
P.O. Box 118
Columbus, OH 43216-0118