



\* 0 H 8 2 0 0 5 1 2 7 2 9 2 0 1 0 N O V \*

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

2195 Front Street  
Logan, Ohio 43138

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

July 29, 2010

Re: **Vinton County  
Village of Zaleski  
Community Public Water System  
PWS ID 8200512**

Village of Zaleski  
PO Box 176  
Zaleski, OH 45698

**Subject: Violation for failure to maintain required chlorine residual**

A review of the Plant Distribution Monthly Operation Reports (Form 5002) for your water system showed that Zaleski failed to maintain an adequate chlorine residual in the distribution system for three or more days each month in the months of April, May and June 2010. Failure to maintain at least 0.2 mg/L free chlorine or 1.0 mg/L combined chlorine constitutes a violation of the Ohio Administrative Code (OAC) Rule 3745-83-01.

The chlorine level on many other days in each month were barely above the minimum. Assuming the chlorination equipment is functioning properly and your chlorine meter is calibrated, either the chlorine solution strength or feed rate may need to be increased. If you have any questions, please contact me at (740) 380-5274.

Sincerely,

Eric Hart  
Environmental Specialist  
Division of Drinking and Ground Waters

EH/cb

cc: C.O., DDAGW  
cc: Vinton County Health Department  
cc: **Jamie Wilkins, SEDO**