**Environmental Protection Agency**
John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH1631112 FOREST HILL LAKE, INC.-CAMP PWS 22 07/22/11

*OH1631112851561 2*

**NOTICE OF VIOLATION – ACTION REQUIRED**

July 22, 2011

RE: Coshocton County
Forest Hill Lake, Inc.-Camp PWS
Non-Community, Transient
PWS ID: OH1631112

Lester Stewart
52176 County Rd. 425
Fresno, OH 43824

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL) During Second Quarter of 2011 (Monthly)**

Forest Hill Lake, Inc.-Camp PWS is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

**Subject: Failure to Sample Drinking Water for Total Coliforms as Required**

Forest Hill Lake, Inc.-Camp PWS is in violation of Ohio Administrative Code (OAC), Rule 3745-81-21 for failure to comply with the total coliform monitoring.

| | |
|---|---|
| **Monitoring Period**: | June 2011 |
| **Required Coliform Monitoring**: | 5 routine per Month |
| **Sample Results Submitted**: | Four |

To ensure the safety of drinking water provided by your system monitoring for total coliforms is essential.

**ACTION REQUIRED**:

1. **Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").

2. **Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.

   - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
   - Mail or other direct delivery to each customer;

**Southeast District Office**
2195 Front Street
Logan, OH 43138-8637

740 | 385 8501
740 | 385 6490 (fax)
www.epa.ohio.gov

- Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;
- Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.

3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - SEDO. Include a copy of each notice distributed, published or posted.

4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact me at this office at 740-380-5229.

Sincerely,

Janet Barth for

Russell Flagg, REHS
Environmental Specialist

RF/cb

Enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

cc: Coshocton County Health Department
Information Management Section, DDAGW, CO
District File Copy

# DRINKING WATER NOTICE

## Tests show coliform bacteria in Forest Hill Lake, Inc.-Camp PWS water

We routinely monitor for the presence of drinking water contaminants. We took 9 samples for coliform bacteria during Apr-June 2011. 2 of those samples showed the presence of coliform bacteria. No more than *1 sample per month* may show the presence of coliform bacteria during a month. During June 2011, we also did not complete all monitoring or testing for total coliform bacteria and therefore cannot be sure of the quality of your drinking water during that time.

## What should I do?

- *You do not need to boil your water or take other corrective actions. However, if you have specific health concerns, consult your doctor. People with severely compromised immune systems, infants, and some elderly people may be at increased risk. These people should seek advice about drinking water from their health care providers.*
- *Total coliform bacteria are generally not harmful themselves. Usually, coliforms are a sign that there could be a problem with the system's treatment or distribution system.*
- *Coliforms are bacteria which are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems. Fecal coliform or E. coli, which are bacteria of greater concern, were not detected in the water.*
- *This notice is to inform you that Forest Hill Lake, Inc.-Camp PWS did not monitor and report results for the presence of total coliform bacteria in the public drinking water system during the June 2011 time period, as required by the Ohio Environmental Protection Agency.*

## What is being done?

We are still detecting coliform bacteria. We are investigating and taking the necessary steps to correct the problem as soon as possible.

For more information, please contact _____ at _____
name of contact phone number

or at _____.
mailing address

General guidelines on ways to lessen the risk of infection by microbes are available from the EPA Safe Drinking Water Hotline at 1(800) 426-4791.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

| | |
|---|---|
| PWSID# OH1631112 | Date Distributed: |

Tier 2: Unresolved Total Coliform Monthly MCL Notice

## PUBLIC NOTICE INSTRUCTIONS AND VERIFICATION FORM FOR NON COMMUNITY PUBLIC WATER SYSTEMS WITH TIER 2 VIOLATIONS

The owner or operator of a non community public water system with a Tier 2 violation or situation shall notify the persons served by the public water system as soon as practical but **no later than 30 days** after the system learns of the violation. Public notice shall be repeated every 3 months as long as the violation or situation persists.

I HEREBY CERTIFY THAT THE PUBLIC WAS NOTIFIED BY THE FOLLOWING METHOD(S) INDICATED BELOW, AS DESCRIBED IN THE OHIO ADMINISTRATIVE CODE RULE 3745-81-32:

| Required Method of Public Notification | Actual Method of Public Notification |
|---|---|
| **Use one or more of the following methods to reach all persons served by the public water system:**<br>1. Public notice issued by posting in conspicuous locations throughout the distribution system (required to remain posted for as long as the violation exists, but in no case less than 7 days<br>2. Public notice issued by mail or other direct delivery to each customer and service connection (where known). | **Describe actual methods used to notify public of the violation:**<br>1A. Dates of posting _____<br>1B. Locations of posting _____<br>_____<br>_____<br>2. Date of mailing/delivery _____ |
| **Schools and Day-Care Facilities** must notify parents or guardians of children being served by methods besides posting, such as a newsletter, e-mail notice, or direct mailing | A. Method(s) _____<br>_____<br>B. Date(s) _____ |
| **If the above methods do not reach all persons served,** also use any other method reasonably calculated to reach other persons served by the system (e.g. publication in a local newspaper or newsletter, use of e-mail to notify employees or students, or delivery of multiple copies to central locations). | A. Method(s) _____<br>_____<br>_____<br>B. Date(s) _____ |

**Please indicate below what public notice was used. INCLUDE A COPY OF THE PUBLIC NOTICE.**

____ A public notice as provided was issued without changes.

____ A different public notice was issued.

_____

Signature of Responsible Person Date

_____

Printed Name and Title of Responsible Person

Forest Hill Lake, Inc.-Camp PWS
OH1631112
Coshocton County
Second Quarter of 2011
Total Coliform Monthly MCL (Vio. Type 22)
&
Total Coliform Monitoring (Vio. Type 24)

**For Ohio EPA use only:**
**Date PN received:** _____
**PN acceptable:** _____ **PN not acceptable:** _____