

www.epa.state.oh.us

2195 Front Street
Logan, Ohio 43138Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director**NOTICE OF VIOLATION – ACTION REQUIRED**

June 30, 2009

RE: Coshocton County
Forest Hill Lake, Inc.-Camp PWS
Non-Community, Transient
PWS ID: OH1631112Lester Stewart
52176 County Rd 425
Fresno, OH 43824**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During Second Quarter of 2009 (Monthly)**

Forest Hill Lake, Inc.-Camp PWS is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.


ACTION REQUIRED:

- 1. Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
 - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
 - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
- 2. Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - SEDO. Include a copy of each notice distributed, published or posted.
- 3. Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

Forest Hill Lake, Inc.-Camp PWS
June 30, 2009
Page 2

If you have any questions, contact this office at 740-380-5421.

Sincerely,

A handwritten signature in black ink that reads "Bob Finkle" with a stylized flourish underneath.

Debra Prim
Environmental Specialist

DP/cb

Enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

cc: Coshocton County Health Department
Information Management Section, DDAGW, CO
District File Copy

DRINKING WATER NOTICE

Tests showed coliform bacteria in Forest Hill Lake, Inc.-Camp PWS water.

We routinely monitor for the presence of drinking water contaminants. We took ten samples for coliform bacteria during June 2009. Three of those samples showed the presence of coliform bacteria. No more than 1 sample per month may show the presence of coliform bacteria during a month.

What should I do?

- *You do not need to boil your water or take other corrective actions. However, if you have specific health concerns, consult your doctor. People with severely compromised immune systems, infants, and some elderly people may be at increased risk. These people should seek advice about drinking water from their health care providers.*
- *Total coliform bacteria are generally not harmful themselves. Usually, coliforms are a sign that there could be a problem with the system's treatment or distribution system.*
- *Coliforms are bacteria which are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.*
- *Fecal coliform or E. coli, which are bacteria of greater concern, were not detected in the follow-up testing.*

What is being done?

Further testing shows that **coliform bacteria are no longer being detected** and this problem has been resolved.

For more information, please contact _____ at _____
name of contact phone number
or at _____
mailing address

General guidelines on ways to lessen the risk of infection by microbes are available from the EPA Safe Drinking Water Hotline at 1(800) 426-4791.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID# OH1631112

Date Distributed:

Tier 2: Resolved Total Coliform Monthly MCL Notice

PUBLIC NOTICE INSTRUCTIONS AND VERIFICATION FORM FOR NON COMMUNITY PUBLIC WATER SYSTEMS WITH TIER 2 VIOLATIONS

The owner or operator of a non community public water system with a Tier 2 violation or situation shall notify the persons served by the public water system as soon as practical but **no later than 30 days** after the system learns of the violation. Public notice shall be repeated every 3 months as long as the violation or situation persists.

I HEREBY CERTIFY THAT THE PUBLIC WAS NOTIFIED BY THE FOLLOWING METHOD(S) INDICATED BELOW, AS DESCRIBED IN THE OHIO ADMINISTRATIVE CODE RULE 3745-81-32:

Required Method of Public Notification	Actual Method of Public Notification
<p>Use one or more of the following methods to reach all persons served by the public water system:</p> <p>1. Public notice issued by posting in conspicuous locations throughout the distribution system (required to remain posted for as long as the violation exists, but in no case less than 7 days)</p>	<p>Describe actual methods used to notify public of the violation:</p> <p>1A. Dates of posting _____</p> <p>1B. Locations of posting _____ _____ _____</p>
<p>If the above methods do not reach all persons served, also use any other method reasonably calculated to reach other persons served by the system or delivery of multiple copies to central locations).</p>	<p>A. Method(s) _____ _____ _____</p> <p>B. Date(s) _____</p>

Please indicate below what public notice was used. INCLUDE A COPY OF THE PUBLIC NOTICE.

___ A public notice as provided was issued without changes.

___ A different public notice was issued.

Signature of Responsible Person Date

Printed Name and Title of Responsible Person

Forest Hill Lake, Inc.-Camp PWS
OH1631112
Coshocton County
Second Quarter of 2009
Total Coliform Monthly MCL (Vio. Type 22)

<p>For Ohio EPA use only: Date PN received: _____ PN acceptable: _____ PN not acceptable: _____</p>
--