



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

April 18, 2013

RE: TRUMBULL COUNTY
CONCORD CARE CTR.-HARTFORD
COMMUNITY WATER SYSTEM
PWS ID# OH7800812
LEAD AND COPPER
NOTICE OF VIOLATION

Ms. Dianne McFarland
Concord Care Center-Hartford
4250 Sodom-Hutchings Road
Cortland, OH 44410

SUBJECT: NOTICE OF VIOLATION FOR FAILURE TO SUBMIT A CORROSION CONTROL RECOMMENDATION AND FAILURE TO PERFORM AND SUBMIT WATER QUALITY PARAMETERS FOR LEAD ACTION LEVEL EXCEEDANCE

Dear Ms. McFarland:

This letter is notification that the Concord Care Center-Hartford water system is in violation of the Ohio Administrative Code (OAC) for failure to submit a corrosion control recommendation for corrosion control equipment and failure to perform and submit water quality parameters as specified in OAC rules 3745-81-80 through 3745-81-89.

In order to avoid any further violations and return to compliance, you must complete the following:

1. **Within 30 days**, you will need to submit a corrosion control recommendation (CCT) and a source water treatment recommendation to this office.
2. **Within 30 days**, monitor with a minimum of two samples for each applicable water quality parameter from:

CONCORD CARE CENTER-HARTFORD
APRIL 18, 2013
PAGE 2

- A. Each entry point to the distribution system; and
- B. One site(s) in the distribution system.

The parameters to measure are pH, water temperature, alkalinity, calcium, conductivity, orthophosphate (when a phosphate inhibitor is used), and silica (when a silicate-containing inhibitor is used).

In addition, monitor with a minimum of one sample for lead and copper at each entry point to the distribution system. Report the results to Ohio EPA-Northeast District office on Form 5108.

Issue the enclosed public notice and return a copy and the verification form to this office within 30 days.

Templates for Form 5108 can be found on our Website at:

www.epa.ohio.gov/ddagw/reporting.aspx#Forms.

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1242.

Sincerely,



Charlotte E. Hammar
Environmental Specialist
Division of Drinking and Ground Waters

CEH:dms

enclosures

cc: Kim Etters, Ohio EPA, DDAGW, NEDO

DRINKING WATER NOTICE

Monitoring requirements not met for the

_____ (PWS Name)

We are required to monitor your drinking water for specific contaminants due to exceeding the action level for lead and or copper during the _____ monitoring period. Results of this monitoring are an indicator of whether or not your drinking water meets health standards. We "did not monitor or test" or "did not complete all monitoring or testing" for pH, water temperature, alkalinity, calcium, conductivity, orthophosphate (when a phosphate inhibitor is used), and silica (when a silicate-containing inhibitor is used). In addition, we did not monitor with a minimum of one sample for lead and copper at each entry point in the distribution system, and therefore cannot be sure of the quality of your drinking water during that time.

What Should I Do?

There is nothing you need to do at this time. You do not need to boil your water or take other corrective action.

What is being done?

Upon being notified of this violation, the water supply was required to have the drinking water analyzed for the above mentioned parameters. The water supplier will take steps to ensure that adequate monitoring will be performed in the future.

For more information, please contact _____ at _____ or _____.
name of contact phone number mailing address

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID# OH	Date Distributed:
-----------	-------------------

