



TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 9, 2008

Re: **HARRISON
MWCD-TAPPAN LAKE PARK
TRANSIENT
OH3401612**

MUSKINGUM WATERSHED CONS DIST
1319 THIRD ST, NW
PO BOX 349
NEW PHILADELPHIA, OH 44663-0349

We have reviewed your PWS Distribution System Monthly Operation Report, covering the time period of June 2008 and have noted the following deficiencies:

- The reported chlorine residual in the distribution system/ plant tap was less than 0.2 mg/L in violation of the Ohio Administrative Code. This occurred on seven separate days, according to the report.

Maintaining a proper chlorine residual helps to ensure that the water will be of a satisfactory sanitary quality. Please takes steps to ensure that at least a 0.2 mg/L free chlorine residual is maintained at all times in the distribution system.

Please take action to correct these deficiencies in your system.

If you have any questions, please contact me at (740) 380-5201.

Sincerely,

Mike Moschell
Inspector
Division of Drinking and Ground Waters

MM/cb

cc: Central Office/DDAGW
cc: Harrison County Health Department
cc: **Jamie Wilkins, SEDO**
cc: John Birney, Tappan Lake Park - PO Box 29, Deersville, Ohio 44693