




OH3735012 ODNR-HOCKING HILLS-CONKLES HOLLOW 22 12/01/08



2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

NOTICE OF VIOLATION – ACTION REQUIRED

December 4, 2008

RE: Hocking County
ODNR-Hocking Hills-Conkles Hollow
Transient Non Community
PWS ID: OH3735012

ODNR Hocking Hills State Park
19852 St Rt 664
Logan, OH 43138

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During November 2008 (Monthly)**

ODNR - Hocking Hills-Conkles Hollow is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

ACTION REQUIRED:

1. **Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served. The appropriate methods for your system are listed below.

Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.


2. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - Southeast District Office. Include a copy of each notice distributed, published or posted.

3. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

ODNR-Hocking Hills-Conkles Hollow
December 4, 2008
Page 2

If you have any questions, contact me at 740-380-5201.

Sincerely,

A handwritten signature in black ink that reads "Bob Lind" with a stylized flourish at the end. Below the name, the word "for" is written in a smaller, cursive script.

Mike Moschell
Inspector

MM/cb

Enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

pc: Hocking County Health Department
Southeast District Office Files
Information Management Section, DDAGW, CO

DRINKING WATER NOTICE

Tests showed coliform bacteria in ODNR-Hocking Hills-Conkles Hollow water.

We routinely monitor for the presence of drinking water contaminants. We took eight samples for coliform bacteria during November 2008. *Three* of those samples showed the presence of coliform bacteria. No more than *1 sample* may show the presence of coliform bacteria during a month.

What should I do?

- *You do not need to boil your water or take other corrective actions. However, if you have specific health concerns, consult your doctor. People with severely compromised immune systems, infants, and some elderly people may be at increased risk. These people should seek advice about drinking water from their health care providers.*
- *Total coliform bacteria are generally not harmful themselves. Usually, coliforms are a sign that there could be a problem with the system's treatment or distribution system.*
- *Coliforms are bacteria which are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.*
- *Fecal coliform or E. coli, which are bacteria of greater concern, were not detected in the follow-up testing.*

What is being done?

Further testing shows that **coliform bacteria are no longer being detected** and this problem has been resolved.

For more information, please contact _____ at _____
name of contact phone number
or at _____
mailing address

General guidelines on ways to lessen the risk of infection by microbes are available from the EPA Safe Drinking Water Hotline at 1(800) 426-4791.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID# OH3735012

Date Distributed:

PUBLIC NOTICE INSTRUCTIONS AND VERIFICATION FORM FOR NON COMMUNITY PUBLIC WATER SYSTEMS WITH TIER 2 VIOLATIONS

The owner or operator of a non community public water system with a Tier 2 violation or situation shall notify the persons served by the public water system as soon as practical but **no later than 30 days** after the system learns of the violation. Public notice shall be repeated every 3 months as long as the violation or situation persists.

I HEREBY CERTIFY THAT THE PUBLIC WAS NOTIFIED BY THE FOLLOWING METHOD(S) INDICATED BELOW, AS DESCRIBED IN THE OHIO ADMINISTRATIVE CODE RULE 3745-81-32:

Required Method of Public Notification	Actual Method of Public Notification
<p>Use one or more of the following methods to reach all persons served by the public water system:</p> <p>1. Public notice issued by posting in conspicuous locations throughout the distribution system (required to remain posted for as long as the violation exists, but in no case less than 7 days)</p>	<p>Describe actual methods used to notify public of the violation:</p> <p>1A. Dates of posting _____</p> <p>1B. Locations of posting _____ _____ _____</p>
<p>If the above methods do not reach all persons served, also use any other method reasonably calculated to reach other persons served by the system (e.g. delivery of multiple copies to central locations).</p>	<p>A. Method(s) _____ _____ _____</p> <p>B. Date(s) _____</p>

Please check if the public notice used was provided by Ohio EPA (other side of this form) or another acceptable notice was used:

_____ A public notice as shown on the other side of this sheet was issued without changes.

_____ A different public notice was issued. **INCLUDE A COPY OF THE PUBLIC NOTICE.**

Signature of Responsible Person Date

Printed Name and Title of Responsible Person

ODNR-Hocking Hills-Conkles Hollow
 OH3735012
 Hocking County
 November 2008
 Total Coliform Monthly MCL (Vio. Type 22)

<p>For Ohio EPA use only: Date PN received: _____ PN acceptable: _____ PN not acceptable: _____</p>
--