



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION

April 17, 2013

Larry D. Cordial
8927 Columbus Road
Mount Vernon, OH 43050

Knox County
Colonial Terrace MHP
COMMUNITY PWS
PWS ID: OH4201512

Subject: Monitoring and Reporting Violation

Dear Public Water System Owner:

The Public Water System serving COLONIAL TERRACE MHP is in violation of the Ohio Administrative Code (OAC) for failure to take a monthly "Special" Raw Water Total Coliform sample from both wells in accordance with the November 13, 2012 Sanitary Survey letter.

Violation Begin Date:	03/01/2013
Required Monitoring:	1 sample each from wells #1 and #2 per month
Sample Results Submitted:	1 from well #1. None from well #2
	Sample #130215202 submitted on 3/4/2013 was rejected by lab for not having enough sample available to run the analysis. A replacement sample was not submitted.

Note chlorine residual levels are required to be collected and reported on the lab sample submission sheet whenever raw samples are collected. The samples should be marked as "Special" purpose and the well identification number recorded in the comment field on the sample submission sheet.

If you have any questions please call your Ohio EPA representative at 614-728-3864.

Sincerely,

Carolyn O'Neal
Environmental Specialist III
Division of Drinking and Ground Waters
Central District Office

ec: CDO DDAGW AA (State Violation)

CO/cl 4201512(MR)MAR2013