



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



**NOTICE OF VIOLATION – ACTION REQUIRED**

April 23, 2013

Mr. Ahmad Jadallah  
Outpost Carryout & Pizza-Walbridge  
28629 East Broadway  
Walbridge, Ohio 43465

Wood County  
Outpost Carryout & Pizza-Walbridge  
Transient Non-Community PWS  
PWS ID: OH8739912

Dear Mr. Jadallah:

This letter is notification that the Outpost Carryout & Pizza-Walbridge has not complied with requirements issued during this Agency's last survey performed on (DATE), in violation of rule 3745-81-60 of the Ohio Administrative Code. The PWS was notified in correspondence dated February 7, 2013, to respond in writing no later than 30 days, with time frames for:

1. According to OAC Rule 3745-7-03, the classification of the Outpost Carryout & Pizza water system is Class A. In accordance with OAC Rule 3745-7-02 (A)(1), the owner or operator of a public water system shall designate an operator of record with a certification of a class equal to or greater than the classification of the public water system, distribution system or water treatment plant. The water system does not currently have an operator of record holding the correct level of certification and is therefore in violation. In order to address this violation:
  - a. Obtain an operator of record to be the on-site certified operator who performs the technical operation of the public water system or each water treatment plant and distribution system within the public water system. Based on the classification listed above, the operator of record must be physically present at the public water system at least 30 minutes per week.


Your public water system may no longer qualify as a Class A public water system. Transient non-community public water systems that serve daily populations greater than two hundred fifty are classified as Class A systems and are required to obtain an operator of record. If your water system serves a population of less than two hundred fifty, provide your daily population numbers to this office with documentation (e.g., sales receipts for one year) in order to declassify your system.

2. A Siting Plan for Total Coliform monitoring was not on file. A Total Coliform Sample Siting Plan template as required by OAC Rule 3745-81-21 was provided during the sanitary survey. Complete the sample siting plan, file it, and update it as necessary.

Mr. Ahmad Jadallah  
April 24, 2013  
Page 2

If you have any questions, please contact me at 419-373-3108 or by e-mail at [janis.damico@epa.ohio.gov](mailto:janis.damico@epa.ohio.gov).

Sincerely,

A handwritten signature in cursive script that reads "Janis D'Amico".

Janis D'Amico  
Division of Drinking and Ground Waters

/cg

pc: DDAGW – NWDO