



www.epa.state.oh.us

2195 Front Street  
Logan, Ohio 43138Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director**NOTICE OF VIOLATION – ACTION REQUIRED**

June 8, 2009

RE: **Pike County**  
**Longs Retreat Well 16**  
**Non-Community, Transient**  
**PWS ID: OH6633712**Eric Long  
50 Bell Hollow Rd  
Latham, OH 45646**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)  
During Second Quarter of 2009 (Monthly)**

Longs Retreat Well 16 is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

**ACTION REQUIRED:**

- 1. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- 2. Notify the people served by this water system.** Post the public notice that was sent to you with the Acute violation letter dated June 3, 2009.
- 3. Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact this office at 740-380-5274 .

Sincerely,

A handwritten signature in black ink, appearing to read "Eric Hart".

Eric Hart  
District Engineer

EH/cb

Enclosures: Tier 2 Public Notification  
Public Notice Instructions and Verification Formcc: Pike County Health Department  
Information Management Section, DDAGW, CO  
**District File Copy**