



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



**NOTICE OF VIOLATION – ACTION REQUIRED**

April 30, 2013

Mr. John Hall  
Payne Village  
P.O. Box 58  
Payne, Ohio 45880

Paulding County  
Payne Village  
Community PWS  
PWS ID: OH6300712

Dear Mr. Hall:

Payne Village is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-91, the public water system failed to maintain hardness within an acceptable range, as set by plan approval, for four occurrences during the month of March 2013.

Payne Village PWS must take immediate action to resolve this violation. Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action.

If you have any questions, please contact me at (419) 373-3007 or by e-mail at [clayton.mckee@epa.ohio.gov](mailto:clayton.mckee@epa.ohio.gov).

Sincerely,

A handwritten signature in black ink, appearing to read "Clayton McKee".

Clayton McKee  
Division of Drinking and Ground Waters

/cg

pc: Paulding County Health Department  
DDAGW – NWDO

ec: Linda Benham, Environmental Supervisor, DDAGW, NWDO  
Clayton McKee, NWDO, DDAGW

