



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



May 3, 2013

**NOTICE OF VIOLATION – ACTION REQUIRED**

Mr. Ron Morningstar  
Oakridge Estates LLC  
643 North High Street  
Hillsboro, Ohio 45133

Marion County  
Oakridge Estates LLC  
Community PWS  
PWS ID: OH5100212

Dear Mr. Morningstar:

Oakridge Estates LLC is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-83-01 (F)(2), the public water system failed to report free chlorine residual daily at the plant tap and in the distribution system during the month of March 2013. There were 23 days during the month in which the analysis was not performed.

Oakridge Estates LLC must take immediate action to resolve this/these violation(s). Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action.

If you have any questions, please call me at 419-373-3108 or by e-mail at [janis.damico@epa.ohio.gov](mailto:janis.damico@epa.ohio.gov).

Sincerely,

Janis D'Amico  
Division of Drinking and Ground Waters

/lir

pc: Marion County Health Department  
DDAGW – NWDO

ec: Ohio Manufactured Homes Commission

