



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

May 7, 2013

Mr. Alvin Smith
Perrysville Village
P.O. Box 85
Perrysville, Ohio 44864

Ashland County
Perrysville Village
Community PWS
PWS ID: OH0301212

Dear Mr. Smith:

Perrysville Village is in violation of Ohio Revised Code Chapter 6109 as follows:

1. In violation of OAC 3745-82-02, the public water system has exceeded the secondary standards for iron which is 0.3 mg/L, and manganese which is 0.05 mg/L. There were 4 weeks during the month of March 2013 in which iron and manganese exceeded the secondary standards.

Monitoring and compliance determinations for the secondary maximum contaminant level for manganese are as follows:

- (a) Public water systems shall use the monitoring required by OAC 3745-83-01(F)(5)(6) to determine compliance with the secondary maximum contaminant levels for iron and manganese.
- (b) A public water system shall be in violation of the secondary standard for iron or manganese when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Violation of the secondary standard for manganese does not require public notification. Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.


Perrysville Village must take immediate action to resolve these violations. Ohio EPA may take action to enforce the requirements of its drinking water rules.

Mr. Alvin Smith
May 7, 2013
Page 2

A civil penalty could be assessed as part of this enforcement action. Your response to this letter is required by June 6, 2013.

If you have any questions, please contact me at (419) 373-3107 or at elizabeth.ames@epa.ohio.gov.

Sincerely,

A handwritten signature in black ink, appearing to read 'Elizabeth Ames', with a long horizontal flourish extending to the right.

Elizabeth Ames
Division of Drinking and Ground Waters

/cg

pc: Scott Reeve
Ashland County Health Department
DDAGW – NWDO