



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Richland County
Heatherwood Community Water System
Community Water System
PWS ID# OH7001712

May 8, 2013

Mr. Ralph Kelsay
Heatherwood Community Water System
788 Woodcrest Drive
Mansfield, Ohio 44905

Dear Mr. Kelsay:

Ohio Administrative Code, Rule 3745-83-01 requires that each community and major non-community water system maintain a minimum of 0.2 mg/l free chlorine residual measured at representative points throughout the distribution system.

Review of your January 2013, operational reports indicate that free chlorine residuals were below this level a total of 10 days.


Review of your February 2013, operational reports indicate that free chlorine residuals were below this level a total of 12 days.

Review of your March 2013, operational reports indicate that free chlorine residuals were below this level a total of 17 days.

An investigation needs to be made to find the cause of these low chlorine residuals and steps need to be taken to bring the water system back to compliance with *OAC Rule 3745-83-01*.

Please note that additional information concerning existing and upcoming drinking water regulations and requirements can be obtained from our Web site at <http://www.epa.ohio.gov>. If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3105 or via email at curt.eldridge@epa.state.oh.us.

Yours truly,


Curtis Eldridge
Environmental Specialist 2
Division of Drinking and Ground Water

/lr

pc: Richland County Health Department
DDAGW-NWDO File

