




John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

May 1, 2013

Bonnie M. Fox
P.O. Box 4205
Newark, OH 43058

Franklin County
Pleasant Acres MHP
COMMUNITY PWS
PWS ID: OH2502912

Dear Ms. Fox:

Pleasant Acres MHP is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-83-01 (C)(1), the public water system failed to maintain the minimum required free chlorine residual in the distribution system when the residual disinfectant concentration of the drinking water at representative points throughout the distribution systems was less than 0.2 mg/L. There were 13 days during the month of March 2013 in which the minimum chlorine residual was not maintained.

Pleasant Acres MHP must take immediate action to resolve these violations. Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action. Please provide a written response as to what corrective actions will be taken within 14 days of the date of this letter.

If you have any questions, please call me by telephone at (614) 728-3864 or via e-mail at carolyn.o'neal@eps.ohio.gov.

Sincerely,

A handwritten signature in cursive script that reads "Carolyn O'Neal".

Carolyn O'Neal
Environmental Specialist III
Division of Drinking and Ground Waters
Central District Office

ec/pc: Manufactured Housing Commission
Franklin County Health Department
CDO DDAGW AA

CO/ct 2502912(MI)MAR2013