


John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



**NOTICE OF VIOLATION – ACTION REQUIRED**

May 1, 2013

Mark Anthony  
15111 State Route 664 South  
Logan, OH 43138

Fairfield County  
Hillview Mobile Village  
COMMUNITY PWS  
PWS ID: OH2302712

Dear Mr. Anthony:

Hillview Mobile Village is in violation of Ohio Revised Code Chapter 6109 as follows:

1. In accordance with Ohio Administrative code (OAC) 3745-83-01(C)(1), community water systems are required to maintain a minimum chlorine residual of at least 0.2 mg/L free or 1.0 mg/L combined chlorine throughout the distribution system. During the month of March, 2013, Hillview Mobile Village failed to maintain a minimum chlorine residual level in the distribution system for 6 days.
2. In accordance with OAC 3745-83-01 (F)(2), the public water system failed to report Plant Tap free or combined chlorine residuals daily. The required daily analysis was not reported for any of the 31 days during the month of March, 2013.

It is noted that these violations have occurred for the fourth consecutive month out of the last 12 months. Hillview Mobile Village must take immediate action to resolve these violations. Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action. A written response to this letter is required within 14 days of the date of this letter identifying the problem and corrective actions necessary to ensure that daily reporting will be provided. If you have any questions, please contact me by telephone at (614) 728-3864 or via email at carolyn.o'neal@epa.ohio.gov.

Sincerely,

Carolyn O'Neal  
Environmental Specialist III  
Division of Drinking and Ground Waters  
Central District Office

ec/pc: Manufactured Housing Commission  
Fairfield County Health Department  
CDO DDAGW AA

CO/cst 2302712(MI)MAR2013