



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

May 1, 2013

Kathryn E. Jenkins
207 W. Columbus Street
P.O. Box 193
Pleasantville, OH 43148

**Fairfield County
Pleasantville Village PWS
COMMUNITY PWS
PWS ID: OH2301712**

Dear Ms. Jenkins:

Pleasantville Village PWS is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for manganese which is 0.05 mg/L. Samples are collected weekly for analysis at a certified lab. There were 2 weeks during the month of March, 2013 in which manganese exceeded the secondary standard. Also, in 2012, manganese levels were exceeded in 7 of the 12 months.

Recommended finished water hardness levels should be maintained between 120-150 mg/L. Frequently throughout 2012 and also in February and March, 2013, hardness levels are reported to have been in the 400's. This needs to be corrected. The problem may be as simple as running out of salt.

As recommended by Ten States Standards, section 4.6.6, total phosphorus (Total P) should not exceed 3.3 mg/L. The public water system exceeded this level in May, 2012 where a value of 174 mg/L was reported. If this value was reported in error, please electronically resubmit a corrected MOR for May, 2012.

These violations do not require public notification however, please review your operations to determine the reason for the high levels and advise our office in writing within 14 days of the date of this letter as to what corrections will be made for each manganese, hardness and total phosphorus.

Kathryn E. Jenkins
Page -2-

If you have any questions, please contact me by telephone at (614) 728-3864 or by e-mail at carolyn.o'neal@epa.ohio.gov.

Sincerely,



Carolyn O'Neal
Environmental Specialist III
Division of Drinking and Ground Waters
Central District Office

ec/pc: Fairfield County Health Department
CDO DDAGW-AA

CO/ct 2301712(MI)MAR2013