



May 14, 2013

NOTICE OF VIOLATION – ACTION REQUIRED

Ms. B. Cheryl Casler
Madison Water District
489 Indiana Avenue
Mansfield, Ohio 44905

Richland County
Madison Water District
Community PWS
PWS ID: OH7006712

Dear Ms. Casler:

Madison Water District is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for manganese which is 0.05 mg/L. There were four (4) weeks during the month in which manganese exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for manganese are as follows:

- (a) A public water system shall be in violation of the secondary standard for manganese when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Madison Water District must take immediate action to resolve this/these violations. Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action. Your response to this letter is required by May 30, 2013.

Beginning July 1, 2013, submit Monthly Operating Reports electronically using the eDWR web application: <http://epa.ohio.gov/ddagw/reporting.aspx>

If you have any questions, please contact me at (419) 373-3105 or by e-mail at curt.eldridge@epa.ohio.gov.

Sincerely,

Curtis Eldridge
Division of Drinking and Ground Waters

/llr

pc: Richland County Health Department
Lonnie McGhee, Operator
DDAGW – NWDO

