

May 14, 2013

**NOTICE OF VIOLATION – ACTION REQUIRED**

Mr. Russell J. Petralia  
Clearfork MHP  
501 Main Street  
Utica, New York 13504

Richland County  
Clearfork MHP  
Community PWS  
PWS ID: OH7000612

Dear Mr. Petralia:

Clearfork MHP is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-83-01(F)(6)(a)(i), the public water system failed to report manganese at the plant tap on a weekly basis. There were three weeks during the month in which no analysis was reported.

In violation of OAC 3745-83-01(F)(5)(a)(i), the public water system failed to report iron at the plant tap on a weekly basis. There were three weeks during the month in which no analysis was reported.

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for iron which is 0.3 mg/L. There was one week during the month in which iron exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for iron are as follows:

- (a) A public water system shall be in violation of the secondary standard for iron when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.


Clearfork MHP must take immediate action to resolve this/these violation(s). Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action. Your response to this letter is required by May 30, 2013.

Beginning July 1, 2013, submit Monthly Operating Reports electronically using the eDWR web application: <http://epa.ohio.gov/ddagw/reporting.aspx>

Mr. Russell J. Petralia  
May 14, 2013  
Page 2

If you have any questions, please contact me at (419) 373-3105 or by e-mail at [curt.eldridge@epa.ohio.gov](mailto:curt.eldridge@epa.ohio.gov).

Sincerely,



Curtis Eldridge  
Division of Drinking and Ground Waters

/llr

pc: Richland County Health Department  
Marc Henke, Operator w/enclosures  
DDAGW – NWDO File

ec: Ohio Manufactured Homes Commission