



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



May 14, 2013

NOTICE OF VIOLATION – ACTION REQUIRED

Ms. Virginia Grose
Walnut Hills Water
552 Morrison Avenue
Mansfield, Ohio 44904

Richland County
Walnut Hills Water
Community PWS
PWS ID: OH7005032

Dear Ms. Grose:

Walnut Hills Water is in violation of Ohio Revised Code Chapter 6109 as follows:


In violation of OAC 3745-83-01(F)(5)(a)(i), the public water system failed to report iron at the plant tap on a weekly basis. There were three (3) weeks during the month in which no analysis was reported.

Walnut Hills Water must take immediate action to resolve this violation. Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action. Your response to this letter is required by May 30, 2013.

Beginning July 1, 2013, submit Monthly Operating Reports electronically using the eDWR web application: <http://epa.ohio.gov/ddagw/reporting.aspx>

If you have any questions, please contact me at (419) 373-3105 or by e-mail at curt.eldridge@epa.ohio.gov.

Sincerely,


Curtis Eldridge
Division of Drinking and Ground Waters
/lr

pc: Richland County Health Department
Marc Henke, Operator
DDAGW – NWDO

