



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



May 14, 2013

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. Randy Pore
Village of Lexington
44 West Main Street
Lexington, Ohio 44904

Richland County
Village of Lexington
Community PWS
PWS ID: OH7002212

Dear Mr. Pore:

Lexington Village is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for iron which is 0.3 mg/L. There were four (4) weeks during the month in which iron exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for iron are as follows:

- (a) A public water system shall be in violation of the secondary standard for iron when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for manganese which is 0.05 mg/L. There were four (4) weeks during the month in which manganese exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for manganese are as follows:

- (a) A public water system shall be in violation of the secondary standard for manganese when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.


Lexington Village must take immediate action to resolve these violations. Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action. Your response to this letter is required by May 30, 2013. Lexington Village must take immediate action to operate treatment units within acceptable standards.

Mr. Randy Pore
May 14, 2013
Page 2

Beginning July 1, 2013, submit Monthly Operating Reports electronically using the eDWR web application: <http://epa.ohio.gov/ddagw/reporting.aspx>

If you have any questions, please contact me at (419) 373-3105 or by e-mail at curt.eldridge@epa.ohio.gov.

Sincerely,



Curtis Eldridge
Division of Drinking and Ground Waters

/llr

pc: Richland County Health Department
DDAGW-NWDO File