




John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



May 16, 2013

Mr. Robert Wells
Village of Vanlue
305 South Buffalo Street
P. O. Box 77
Vanlue, Ohio 45890

Hancock County
Village of Vanlue
Community PWS

PWS ID: OH3248312

Dear Mr. Wells:

Village of Vanlue is in violation of Ohio Revised Code Chapter 6109 as follows:


Increase the by-pass water to bring the hardness within the 80 to 150 mg/l range.

Village of Vanlue must take immediate action to operate treatment units within acceptable standards.

Beginning July 1, 2013, submit Monthly Operating Reports electronically using the eDWR web application: <http://epa.ohio.gov/ddagw/reporting.aspx>

If you have any questions, please contact me at (419) 373-3105 or by e-mail at curt.eldridge@epa.ohio.gov.

Sincerely,



Curtis Eldridge
Division of Drinking and Ground Waters

/llr

pc: Hancock County Health Department
DDAGW – NWDO File

