



**Environmental  
Protection Agency**

**John R. Kasich, Governor**  
**Mary Taylor, Lt. Governor**  
**Scott J. Nally, Director**



February 27, 2013

Mike Winners  
Paulding Village  
901 McDonald Pike  
Paulding, OH 45879

Paulding County  
Paulding Village  
Community PWS  
PWS ID: OH6300411

Dear Mr. Winners,

It has been determined that Paulding Village was not in violation of the maximum contaminant level (MCL) for TTHM running annual average during the October 1 to December 31, 2012 time period. Therefore, the MCL violation that was issued on February 21, 2013 is rescinded and Paulding Village is not required to issue a public notice as outlined in the notice of violation.

The calculation of the running annual average was incorrectly stated as 0.081 mg/L when it should actually be 0.0835 mg/L.

In order to remain in compliance, you must continue to monitor for all chemical parameters as indicated on your most recent monitoring schedule.

If you have any questions, please contact me at (614) 644-2752.

Sincerely,

Michael W. Deal  
Compliance Assurance Section  
Division of Drinking and Ground Waters

cc: Summit County Health Department