



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

May 21, 2013

RE: HUKILL ENVIRONMENTAL SERVICES
TSD/LQG/TRANSPORTER
OHD001926740/02-18-0315
CUYAHOGA COUNTY, NOV/PRTC

Mr. Frank Simcic
EH&S Manager
Hukill Environmental Services
7013 Krick Road
Bedford, OH 44146

Dear Mr. Simcic:

Thank you for your email response of May 10, 2013, to my April 29, 2013 notice of violation/partial return to compliance letter. Your response included a timeline for the completion of the concrete tank dike's containment repair and coating and answers to the comments found in the letter.

Ohio EPA finds the timeline acceptable. However, the following two violations noted during the April 10 and 17, 2013 inspection will remain outstanding until completion of the project. Violation number one was previously abated.

2 & 3. OAC 3745-55-93(E)(1)(c)&(f)-Tank external liner systems.

External liner systems must be free of cracks and gaps (OAC 3745-55-93(E)(1)(f)) and provided with an impermeable interior coating or lining that is compatible with the stored waste and that will prevent migration of wastes into the concrete (OAC 3745-55-93(E)(1)(c)).

The three outdoor, concrete tank dikes' secondary containment coating is starting to flake off the walls and all the dikes have some cracks in their floor and walls. There is also a buildup of debris within the tank dikes.

Your response letter stated that you will keep me informed of project progress. Upon completion of the project please submit a summary of pertinent activities and a certification statement that all cracks have been properly repaired and that the dikes were coated with an impermeable interior coating that is compatible with the stored waste and will prevent migration of wastes in the concrete.

HUKILL ENVIRONMENTAL SERVICES
MAY 21, 2013
PAGE – 2 –

You can find copies of the rules and other information on the division's web page at <http://www.epa.state.oh.us/dmwm.aspx>

Should you have any questions, please feel free to call me at (330) 963-1162 or email me at marlene.kinney@epa.state.oh.us

Sincerely,

A handwritten signature in cursive script that reads "Marlene M. Kinney". The signature is written in black ink and is positioned above the typed name.

Marlene M. Kinney
Environmental Specialist
Division of Materials and Waste Management

MMK:ddw

ec: Jeff Mayhugh, DMWM, CO
Nyall McKenna, DMWM, NEDO
Natalie Oryshkewych, DMWM, NEDO