



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 7, 2007

**Re: Vinton County
Industrial Timber and Lumber
0682000006 B001
Compliance Test
Certified Mail 7063450000190546314**

Mr. Larry Hensley
Industrial Timber and Lumber
36748 State Route 93
Hamden, Ohio 45634

Dear Mr. Hensley:

On April 3, 2007, AST Environmental Inc. performed a particulate emission compliance test at Industrial Timber and Lumber, 36748 State Route 93, Hamden on the 18 million Btu wood fired boiler (Emissions Unit B001). Ohio EPA received the test report on May 4, 2007. The test report has been reviewed and we have concluded that the test was conducted according to the procedures specified in 40 CFR Part 60, Appendix A, U.S. EPA Test Method(s) 1-5. The results of the test showed the source to be out of compliance with the applicable Ohio EPA regulations and your facility permit terms and conditions.

Our test review shows the following:

- A. Tested Emission Rate: 0.353 lb/million btu
- B. Allowable Emission Rate: 0.030 lb/million btu
- C. Source Operating Rate: 17 million btu/hr
- D. Isokinetic Rate: Run #1 - 92%; Run #2 - 93%; Run #3 - 95%

Please submit to this office, within 30 days of receipt of this letter, a plan and schedule for achieving compliance. Submit this plan to the attention of Steve Alspach.


Acceptance by Ohio EPA of a compliance plan and schedule does not constitute a waiver of Ohio EPA's authority to seek civil penalties as provided in Section 3704.06 of the Revised Code. The determination to pursue or to decline to pursue such penalties in this case will be made by Ohio EPA at a later date.

Industrial Timber and Lumber
June 7, 2007
Page 2

Please refer any questions concerning the above requirements to Steve Alspach, Ohio EPA Southeast District Office, at (740) 380-5424.

Thank you for your cooperation in this matter.

Sincerely,



Steve Alspach
Environmental Specialist
Division of Air Pollution Control

SA/dh

cc: Steve Alspach (Emissions Unit File Copy)
Dean Ponchak, DAPC, SEDO w/CETA summary attachment
Lisa Holscher, U.S. EPA Region V
Tom Kalman, DAPC, CO
Test Report File Copy

DIVISION OF AIR POLLUTION CONTROL-SEDO
CETA APPENDIX K DATA
Stack Test Review Summary Form

FACILITY INFORMATION

FACILITY NAME: Industrial Timber and Lumber

COUNTY: Vinton

FACILITY ID: 0682000006 B001

SCC: 1 02 009 03

EMISSION TEST INFORMATION

POLLUTANT(S) TESTED: particulate

INTENT TO TEST (ITT) NOTIFICATION SUBMITTED: March 19, 2007

SCHEDULED TEST DATE FROM ITT: April 3, 2007

TESTING FIRM: AST Environmental, Inc

DATE TEST CONDUCTED: April 3, 2007

DAPC-SEDO TEST OVERSIGHT

NAME OF DAPC-SEDO STAFF WITNESS: Lisa Duvall

WERE ALL RUNS WITNESSED? NO
*IF NO PROVIDE EXPLANATION: problem with source

IS STACK TEST FIELD FORM COMPLETE? YES

WERE AUDIT SAMPLES TAKEN? NO

EMISSION UNIT INFORMATION

EMISSION UNIT ID#: B001

EMISSION UNIT DESCRIPTION: 18 million Btu wood fired boiler

EMISSION UNIT MONITORING AND CONTROL

LIST EU MONITORING EQUIPMENT: none

LIST EU CONTROL EQUIPMENT: cyclone

TEST REPORT

TEST REPORT REVIEWER: Lisa Duvall

DATE TEST REPORT RECEIVED AT SEDO: May 4, 2007

POLLUTANT: particulate TEST METHOD: 1-5
ALLOWABLE EMISSION RATE (UNITS): 0.030 lb/mm btu
AVERAGE TEST EMISSION RATE (UNITS): 0.353 lb/mm btu
MAXIMUM PERMITTED OPERATING RATE FOR EU: 18 mm btu/hr
AVERAGE TEST OPERATING RATE FOR THE THREE RUNS: 17 mm btu/hr
TEST PASSED NO
DATE TEST RESPONSE LETTER SENT TO FACILITY: June 4, 2007

I HEREBY VERIFY THAT THE INFORMATION CONTAINED WITHIN THE STACK TEST REPORT HAS BEEN REVIEWED AND IT HAS BEEN DETERMINED THAT THE TEST PROCEDURES, ANALYSES, AND CALCULATIONS ARE:

- [X] AN ACCEPTABLE DEMONSTRATION OF CONFORMANCE WITH THE APPROVED TESTING METHODOLOGY**
- [] AN UNACCEPTABLE DEMONSTRATION OF CONFORMANCE WITH THE APPROVED TESTING METHODOLOGY**

May 30, 2007

Date of Review

Lisa Duvall

Reviewed by