



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 4, 2008

**RE: Vinton County
Industrial Timber and Lumber
0682000006 B001
COMPLIANCE TEST
CERTIFIED: 70063450000190563663**

Larry Hensley
Industrial Timber and Lumber
35748 State Route 93
Hamden, OH 45634

Dear Mr. Hensley:

On October 23, 2007, Emissions and Source Testing Company performed a particulate emission compliance test at Industrial Timber and Lumber on the 18 million Btu/hour wood-fired boiler (Emissions Unit B001). Ohio EPA received the test report on November 29, 2007. The test report has been reviewed and we have concluded that the test was conducted according to the procedures specified in 40 CFR Part 60, Appendix A, U.S. EPA Test Methods 1-5. The results of the test showed the source to be out of compliance with the applicable Ohio EPA regulations and your facility permit terms and conditions.

Our test review shows the following:

Tested Emission Rate:	0.315 pound particulate emissions/million Btu heat input
Allowable Emission Rate:	0.30 pound particulate emissions/million Btu heat input
Source Operating Rate:	11.0 million Btu/hour heat input
Isokinetic Rates:	Run #1 – 91.7%; Run #2 – 95.8%; Run #3 – 97.4%

The conclusions above are based on the information provided to Ohio EPA via the test report received on November 29, 2007. We also made an attempt to identify and evaluate other potential operational or test-related factors that may have contributed to the discrepancy between the unit's operating rate and the emission test results. We were not able to definitively identify any specific factor that would have lead to the discrepancy mentioned above. If you have additional information which would confirm an alternate conclusion, please provide this additional information to this office. Please include a detailed explanation which substantiates any alternate conclusions. If you are unable to offer a substantiated alternate conclusion, please submit to this office, within 30 days of receipt of this letter, a plan and schedule for achieving compliance. Submit this plan to the attention of Steve Alspach.


Larry Hensley
Industrial Timber and Lumber
December 4, 2008
Page 2

Acceptance by Ohio EPA of a compliance plan and schedule does not constitute a waiver of Ohio EPA's authority to seek civil penalties as provided in Section 3704.06 of the Revised Code. The determination to pursue or to decline to pursue such penalties in this case will be made by Ohio EPA at a later date.

Please refer any questions concerning the above requirements to Steve Alspach, Ohio EPA Southeast District Office, at 740-380-5424

Thank you for your cooperation in this matter.

Sincerely,



Bruce Weinberg
Environmental Manager
Division of Air Pollution Control

BW/mlm

cc: Steve Alspach, (Emissions Unit File Copy)
Dean Ponchak, DAPC-SEDO w/ CETA summary attachment
Test Report File Copy