

**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

March 7, 2011

**RE: Vinton County  
Industrial Timber & Lumber Co.  
0682000006, EU: B001  
COMPLIANCE TEST  
Non-HPV Violation**

**Certified: 70101060000178961856**

Larry Hensley and  
Larry Evans  
Industrial Timber & Lumber Co.  
35748 SR 93  
Hamden, OH 45634

Dear Mr. Hensley:

On September 16, 2009, Analytical Testing Consultants, Inc. performed a particulate emissions compliance test at the Hamden Plant, 35748 State Route 93, Hamden, OH on the 18.0 MMBtu/hr wood fired boiler (Emissions Units B001). Ohio EPA received the test report on November 2, 2009. The test was conducted to meet the permit-to-install and operate requirements for B001, P0041953, issued on May 26, 1995, and to demonstrate compliance due to failed emissions tests. The test report has been reviewed and we have concluded that the test was conducted according to the procedures specified in 40 CFR Part 60, Appendix A, U.S. EPA Test Methods 1 – 5. The results of the test showed EU B001 to be out of compliance with the applicable Ohio EPA regulations and your facility permit terms and conditions.

<b>B001 – 18 MMBtu/hr woodfired boiler</b>	<b>Particulate matter</b>
<b>Tested Emission Rate:</b>	0.307 lbs/MMBtu
<b>Allowable Emission Rate:</b>	0.30 lbs/MMBtu
<b>Source Operating Rate:</b>	13.690 MMBtu/hr (18 MMBtu/hr Max)

06-1335

Ohio EPA is requesting Industrial Timber and Lumber (ITL) submit a Plan and Schedule for implementing any needed improvements, controls, corrections to control emissions, with updated/corrected Permit to Install/Operate renewal applications for B001, to the Ohio EPA Southeast District Office within 90 days of receipt of this letter. The Plan and Schedule must explain (list) the actions ITL intends to undertake or has already implemented to return to compliance and specify the date anticipated for completion of each action in the plan.


Larry Hensley / Larry Evans  
Industrial Timber & Lumber Co.  
March 7, 2011  
Page 2

Acceptance by Ohio EPA of a compliance plan and schedule does not constitute a waiver of Ohio EPA's authority to seek civil penalties as provided in Section 3704.06 of the Revised Code. The determination to pursue or to decline to pursue such penalties in this case will be made by Ohio EPA at a later date.

All test information will be used by Ohio EPA personnel for permit processing and source compliance review. Please refer any questions concerning the above requirements to Steve Alspach, Ohio EPA Southeast District Office, at (740) 380-5424.

Thank you for your cooperation in this matter.

Sincerely,



Marco Deshaies  
Environmental Specialist  
Division of Air Pollution Control

MD/mlm

cc: Steve Alspach, DAPC-SEDO (Emissions Unit File Copy)  
Marco Deshaies, DAPC-SEDO  
Bruce Weinberg, DAPC-SEDO  
Test Report File Copy