



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 27, 2007

Spectra Energy -Somerset

Compressor Station

Facility ID #055010007

~~Madison County~~ **2007 Compliance Inspection**

Warning Letter

Certified: 70063450000190561164

0664000100
~~055010007~~
Perry County

Noah P. Minge
Spectra Energy Transmission, LLC
PO Box 270
Batesville, IN 47006

Dear Mr. Minge:

On September 5, 2007, I met with you and Charles South to conduct a Title V inspection at your Somerset, Ohio facility. The inspection was conducted to determine the facility's compliance with state and federal air pollution rules and regulations. There are currently eight non-insignificant sources permitted at your facility:

- B001 - Reciprocating compressor engine 21501
- B002 - Reciprocating compressor engine 21502
- B003 - Reciprocating compressor engine 21503
- B004 - Reciprocating compressor engine 21504
- B005 - Reciprocating compressor engine 21505
- B006 - Reciprocating compressor engine 21506
- B007 - Reciprocating compressor engine 21507
- B009 - Gas Turbine 12401

At the time of the inspection, B009 was in operation and appeared to be in compliance. B001-B007 were in the process of being shut down for a line replacement, and shortly after my arrival this shutdown was complete.


Spectra Energy - Somerset Compressor Station was issued a Title V permit on May 27, 1999, which expired on May 27, 2004, and Ohio EPA received a renewal application on December 4, 2003. The renewal application is currently in review at this office.

During the inspection, I also reviewed your records, as required by your Title V permit. At the time of the inspection, the rolling, 365-day summation of the combined operating hours for emissions units B001-B007 was not being kept as required by Part III, Section A. III. 1. b of your Title V permit. Please provide me with a compliance plan and schedule within 14 days of the receipt of this letter detailing how you will meet this requirement. All other records appear in order.

Noah P. Minge
Spectra Energy Transmission, LLC
September 27, 2007
Page 2

I would like to thank you and Charles for your assistance with this inspection. A copy of the inspection forms are attached for your records. If you have any questions or need additional information, please contact me by phone at (740) 380-5234 or email at joseph.laughery@epa.state.oh.us.

Sincerely,



Joseph H. Laughery
Environmental Specialist
Division of Air Pollution Control

JHL/mlm

Enclosure

cc. Charles South (w/ enclosure)